

**Government of Bihar
Public Health Engineering Department**

Division Name : P.H. Division: Saharsa

District Name: Saharsa

Sample given by- Shanti Niketan Shikshan Sansthan, Saharsa Sample collection Date- 13.01.2017

Testing Date - 13.01.2017

Sl. No.	Block	Panchyat	Village	Location of Source	Parameters													Bacteriologic al/ Tested by H ₂ S Strip Vial	Type of Contamin ation found	Remarks (Safe or Unsafe)
					pH	Turb	TH	Alka	Ca	Cl	Fe	NO ₃	SO ₄	TDS	As	F				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
1	Sattark ataiya	Bishanpur	Menha	Hand Pump No-02	6.5	1	60	20	16	20	0.1	BDL	14	136	BDL	0.5	-	-	Safe	
2	Sattark ataiya	Bishanpur	Menha	High Yielding Tubewell	6.6	1	50	18	14	18	0.1	BDL	12	128	BDL	0.5	-	-	Safe	
Desirable Limit*					6.5- 8.5	1	200	200	75	250	0.3	45	200	500	0.01	1.0	-	-	-	
Permissible Limit* in absence of Alternate source In					5	600	600	200	1000	1.0	NR	400	2000	NR	1.5	-	-	-	-	

[Signature]
16/10/17
Officist
P.H.Div., Saharsa

[Signature]
Executive Engineer
P.H.Division, Saharsa.
Executive Engineer
P.H. Div. No. 1, SAHARSA

[Signature]
Manager
Shanti Niketan Shikshan Sansthan
Menha Saharsa-Bihar

[Signature]
Principal
Shanti Niketan Shikshan Sansthan
Affiliated to CBSE, Aff. No - 330512
Menha, Saharsa-852124