

ANNEXURE - C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref. No. 2021

Dated: 03/08/2026

It is certified that an inspection team headed by Mr. Amar Kumar

(Chemist) (Name of Officers with designation) from Public

Health Division, Saharsa PHED inspected the Shanti Niketan

Shikshan Sansthan, Menha, P.S. - Bihar, P.O. Khadimbura, Saharsa, Bihar - 852124

(Name & Address of the school) on 30.07.2026 (date of inspection) and on the basis of Water

Test Report (Attached) bearing no SHR/W/26-27/42 dated 01.08.2026 of

D.L.W.T.L., Saharsa (PHED Lab) certified that the

Shanti Niketan Shikshan Sansthan, Menha, Bihar, Khadimbura, Saharsa, Bihar - 852124

(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The Certificate is valid till Three Months.

Date: 01.08.2026

Signature with seal:

01/08/26
Executive Engineer
P.H. Division, Saharsa

Place: P.H. DIVISION,
SAHARSA

Name:

Mr. AKASH SAHANI

Designation:

EXECUTIVE ENGINEER

Name & Address of the Office/Department: P. H. DIVISION,

SAHARSA, BIHAR, PIN No. - 852201

To

The Principal,

Shanti Niketan Shikshan Sansthan, Menha, Saharsa.

(Name & Address of the Institution)



TC-14409

TEST REPORT

Name & Address Of the Customer : SHANTI NIKETAN SHIKSHAN SANSTHAN Menha, P.S.-Bihra, P.O.-Khadimpur, Saharsa, Bihar-852124 Location: Hand Pump -01	Report No.	SHR/W/26-27/ 42
	Date of Issue of Report	01.08.2026
	Sample No.	SHR/W/26-27/42
	Sample Description	Drinking Water
	Sample Mark/ Location	Raw Water
	Sample Collected On	29.07.2026
	Sample Collected and Provided by	Customer
	Sampling Plan & Method	IS 3025(Part 1): 1987 (RA 2019)
	Date of Performance (s)	01.08.2026
	Ref No. Date	

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012 Amd. 1 & 2 RA		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	5
2	Odour	IS 3025 (Part 5) : 2018	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	6.50
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	<1
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	308
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	152.00
8	Calcium (mg/l)	IS 3025(Part 40) : 2024	75	200	40.00
9	Magnesium (mg/l)	APHA 24th Edition - 2023:3500 - Mg B	30	100	12.63
10	Chloride (mg/l)	IS 3025(Part 32) : 2025	250	1000	55.98
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	140.00
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1.00	NR	0.04

Disclaimer:

The result relates only to the item(s) tested as received.
The report shall not be reproduced except in full, without approval of the laboratory.
The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
Test Performed at temperature 25± 4°C & 60± 20% Relative Humidity.
This test report shall not be used for legal/advertisement purpose.

For PHED Laboratory, Saharsa

Reviewed & Authorized By


Name : Mr. Amar Kumar
(Authorized Signatory)

Chemist
D.L.W.T. Lab.
Saharsa

(End of Report)



TEST REPORT

Name & Address Of the Customer : SHANTI NIKETAN SHIKSHAN SANSTHAN Menha, P.S.-Bihra, P.O.-Khadimpur, Saharsa, Bihar-852124 Location: Hand Pump -02	Report No.	SHR/W/26-27/ 43
	Date of Issue of Report	01.08.2026
	Sample No.	SHR/W/26-27/43
	Sample Description	Drinking Water
	Sample Mark/ Location	Raw Water
	Sample Collected On	29.07.2026
	Sample Collected and Provided by	Customer
	Sampling Plan & Method	IS 3025(Part 1): 1987 (RA 2019)
	Date of Performance (s)	01.08.2026
	Ref No. Date	

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012 Amd. 1 & 2 RA		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	5
2	Odour	IS 3025 (Part 5) : 2018	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	6.52
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	<1
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	170
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	80.00
8	Calcium (mg/l)	IS 3025(Part 40) : 2024	75	200	16.00
9	Magnesium (mg/l)	APHA 24th Edition - 2023:3500 - Mg B	30	100	9.72
10	Chloride (mg/l)	IS 3025(Part 32) : 2025	250	1000	33.98
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	80.00
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1.00	NR	0.28

Disclaimer:

The result relates only to the item(s) tested as received.
The report shall not be reproduced except in full, without approval of the laboratory.
The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
Test Performed at temperature 25± 4°C & 60± 20% Relative Humidity.
This test report shall not be used for legal/advertisement purpose.


For PHED Laboratory, Saharsa

Reviewed & Authorized By

Name : Mr. Amar Kumar
(Authorized Signatory)

Chemist
D.L.W.T. Lab.
Saharsa

(End of Report)



TEST REPORT

Name & Address Of the Customer : SHANTI NIKETAN SHIKSHAN SANSTHAN Menha, P.S.-Bihra, P.O.-Khadimpur, Saharsa, Bihar-852124 Location: Boring -01	Report No.	SHR/W/26-27/ 44
	Date of Issue of Report	01.08.2026
	Sample No.	SHR/W/26-27/44
	Sample Description	Drinking Water
	Sample Mark/ Location	Raw Water
	Sample Collected On	29.07.2026
	Sample Collected and Provided by	Customer
	Sampling Plan & Method	IS 3025(Part 1): 1987 (RA 2019)
	Date of Performance (s)	01.08.2026
	Ref No. Date	

Analysis Result


Sl. No.	Test Parameter	Test Method	IS 10500:2012 Amd. 1 & 2 RA		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	5
2	Odour	IS 3025 (Part 5) : 2018	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	6.50
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	<1
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	186
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	92.00
8	Calcium (mg/l)	IS 3025(Part 40) : 2024	75	200	19.84
9	Magnesium (mg/l)	APHA 24th Edition - 2023:3500 - Mg B	30	100	10.69
10	Chloride (mg/l)	IS 3025(Part 32) : 2025	250	1000	35.98
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	84.00
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1.00	NR	0.13

Disclaimer:

The result relates only to the item(s) tested as received
The report shall not be reproduced except in full, without approval of the laboratory.
The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
Test Performed at temprature 25± 4°C & 60± 20% Relative Humidity.
This test report shall not be uses for legal/advertisement purpose.


For PHED Laboratory, Saharsa

Reviewed & Authorized By


Name :Mr. Amar Kumar
(Authorized Signatory)

Chemist
D.L.W.T. Lab.
Saharsa

(End of Report)



TEST REPORT

Name & Address Of the Customer : SHANTI NIKETAN SHIKSHAN SANSTHAN Menha, P.S.-Bihra, P.O.-Khadimpur, Saharsa, Bihar-852124 Location: Boring -02	Report No.	SHR/W/26-27/ 45
	Date of Issue of Report	01.08.2026
	Sample No.	SHR/W/26-27/45
	Sample Description	Drinking Water
	Sample Mark/ Location	Raw Water
	Sample Collected On	29.07.2026
	Sample Collected and Provided by	Customer
	Sampling Plan & Method	IS 3025(Part 1): 1987 (RA 2019)
	Date of Performance (s)	01.08.2026
	Ref No. Date	

Analysis Result


Sl. No.	Test Parameter	Test Method	IS 10500:2012 Amd. 1 & 2 RA		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	5
2	Odour	IS 3025 (Part 5) : 2018	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	6.58
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	<1
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	108
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	52.00
8	Calcium (mg/l)	IS 3025(Part 40) : 2024	75	200	11.20
9	Magnesium (mg/l)	APHA 24th Edition - 2023:3500 - Mg B	30	100	5.83
10	Chloride (mg/l)	IS 3025(Part 32) : 2025	250	1000	19.99
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	60.00
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1.00	NR	0.03

Disclaimer:

The result relates only to the item(s) tested as received
The report shall not be reproduced except in full, without approval of the laboratory.
The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
Test Performed at temperature 25± 4°C & 60± 20% Relative Humidity.
This test report shall not be used for legal/advertisement purpose.

For PHED Laboratory, Saharsa

Reviewed & Authorized By


Name :Mr. Amar Kumar
(Authorized Signatory)

Chemist
D.L.W.T. Lab.
Saharsa

(End of Report)